

Fusion of Microgrid Control With Model-Free Reinforcement Learning: Review and Vision

Buxin She^{1b}, *Student Member, IEEE*, Fangxing Li^{1b}, *Fellow, IEEE*, Hantao Cui^{1b}, *Senior Member, IEEE*,
Jingqiu Zhang^{1b}, *Student Member, IEEE*, and Rui Bo^{1b}, *Senior Member, IEEE*

Abstract—Challenges and opportunities coexist in microgrids as a result of emerging large-scale distributed energy resources (DERs) and advanced control techniques. In this paper, a comprehensive review of microgrid control is presented with its fusion of model-free reinforcement learning (MFRL). A high-level research map of microgrid control is developed from six distinct perspectives, followed by bottom-level modularized control blocks illustrating the configurations of grid-following (GFL) and grid-forming (GFM) inverters. Then, mainstream MFRL algorithms are introduced with an explanation of how MFRL can be integrated into the existing control framework. Next, the application guideline of MFRL is summarized with a discussion of three fusing approaches, i.e., model identification and parameter tuning, supplementary signal generation, and controller substitution, with the existing control framework. Finally, the fundamental challenges associated with adopting MFRL in microgrid control and corresponding insights for addressing these concerns are fully discussed.

Index Terms—Microgrid control, data-driven control, model-free reinforcement learning, grid-following and grid-forming inverters, review and vision.

I. INTRODUCTION

MICROGRIDS are gaining popularity due to their capability for accommodating distributed energy resources (DERs) and form a self-sufficient system [1]. Microgrids not only contribute to the development of a zero-carbon city but also work as a fundamental component of the ‘source, network, and load’ integrated energy systems. A microgrid may incorporate various types of energy sources and act as an energy router [2], making it possible for the grid to

survive severe events while also making the country more energy-resilient and secure [3].

A typical microgrid is composed of various DERs, energy storage systems, and loads that are connected locally as a united controlled entity [4]. In comparison to a traditional synchronous generator-dominated bulk power system, microgrids have a larger penetration of DERs [5], [6], a smaller system size [7], a greater degree of uncertainty [8], lower system inertia [9], [10], and a stronger coupling of voltage and frequency (V-f). All these features pose challenges to the design of a microgrid control system. A complete microgrid control system is comprised of software and hardware that can both perform microgrid functionalities and guarantee stability at the same time [11]. The software is also referred to as microgrid controllers, and focuses on control algorithm design in the paper. Existing microgrid controllers are usually designed under a hierarchical framework that includes the primary, secondary, and tertiary controllers [12]. Ref. [13] conducted a thorough review of the hierarchical control of microgrids. There are also some articles providing an overview from the different perspectives of communication interfaces [14], operation modes [15], and control techniques [16]. All these reviews provided an excellent summary and future directions of microgrid control research. As a result, we synthesize the valuable viewpoints and develops a high-level research map of microgrid control based on existing work. Furthermore, modularized control blocks have been developed to dive into the design of the fundamental units of microgrids: grid-following (GFL) and grid-forming (GFM) inverters [17], which is advantageous for microgrid researchers.

Model-free controllers have been used previously in microgrid control because they are easy to set up and independent of the physical model of the microgrid components. For example, fuzzy logic controllers [18], [19] and adaptive controllers [20], [21] can adjust their output based on predefined membership functions and adaption laws, respectively. However, they are difficult to scale up and cannot deal with emerging uncertainties in microgrids. Neural network control [22], [23] is another type of well-known model-free method. Although neural network is good at perception and decision-making based on historical data, it lacks exploration capability and cannot adapt to the rapidly changing microgrid environment. Apart from the above-mentioned model-free techniques, reinforcement learning (RL) is a prominent approach that is concerned with how an intelligent agent learns to solve Markov Decision Processes (MDP) in an environment. If we do not assume knowledge or an exact mathematical model of the

Manuscript received 4 June 2022; revised 6 October 2022; accepted 11 November 2022. Date of publication 15 November 2022; date of current version 21 June 2023. This work was supported in part by the U.S. Environmental Security Technology Certification Program (ESTCP) under Grant EW20-EO-5331. Paper no. TSG-00794-2022. (*Corresponding author: Fangxing Li.*)

Buxin She and Fangxing Li are with the Department of Electrical Engineering and Computer Science, The University of Tennessee at Knoxville, Knoxville, TN 37996 USA (e-mail: bshe@vols.utk.edu; fli6@utk.edu).

Hantao Cui is with the Department of Electrical and Computer Engineering, Oklahoma State University, Stillwater, OK 74078 USA (e-mail: h.cui@okstate.edu).

Jingqiu Zhang is with the Department of Electrical and Computer Engineering, National University of Singapore, Singapore (e-mail: jingqiuzhang@u.nus.edu).

Rui Bo is with the Department of Electrical and Computer Engineering, Missouri University of Science and Technology, Rolla, MO 65409 USA (e-mail: rbo@mst.edu).

Color versions of one or more figures in this article are available at <https://doi.org/10.1109/TSG.2022.3222323>.

Digital Object Identifier 10.1109/TSG.2022.3222323

environment, RL is referred to as model-free reinforcement learning (MFRL). Then, the RL agent finds the optimal policy through repeated interactions with the environment [24], [25]. MFRL is a promising data-driven and model-free approach since it is not dependent on an accurate system model and does not need as many labeled datasets as supervised learning. In addition, it has strong exploration capability and can achieve autonomous operation once set up. MFRL is gaining more and more attention due to its successful applications in video games [26], autonomous driving [27], robotics [28], and power systems [29]. Recently, researchers from DeepMind and École Polytechnique Fédérale de Lausanne developed a non-linear, high-dimensional, and RL-based magnetic controller for nuclear fusion [30] and published their work in *Nature*. This indicates the great potential of implementing MFRL in engineering control (microgrid control).

For now, MFRL is still under development and needs further study. While some research has been conducted on MFRL for its application in microgrid control, there has been no in-depth review of how MFRL can be integrated into the current microgrid control framework. Hence, this paper performs a comprehensive review of the control framework of microgrids and summarizes how MFRL fuses with the existing control schemes.

Compared with other review papers on microgrid control, the main merits of this manuscript include:

- Plotting of a high-level research map of microgrid control from the perspective of operation mode, function grouping, timescale, hierarchical structure, communication interface, and control techniques.
- Development of modularized control blocks to dive into the fundamental units of microgrids: GFL and GFM inverters.
- Introduction of the mainstream MFRL algorithms and summary of MFRL application guidelines, and the answering of two important questions: *i)* ‘What kinds of tasks is MFRL suitable for?’; *ii)* ‘How can MFRL be fused with the existing microgrid control framework?’.
- Discussion of the primary challenges associated with adopting MFRL in microgrid control and providing insights for addressing these concerns.

The rest of this paper is organized as follows. Section II introduces the current microgrid control framework, including a high-level research map and modularized control blocks. Section III gives a brief introduction to RL and the mainstream algorithms of MFRL. The characteristics of each algorithm and its application scenarios in microgrid control are also summarized. A full discussion of the fusion of microgrid control with MFRL is presented in Section IV, along with the associated challenges and insights. Section V concludes this paper.

II. MICROGRID CONTROL FRAMEWORK

This section first plots a high-level research map of microgrid control, and then develops modularized control blocks to dive into GFL and GFM inverters.

A. High-Level Research Map of Microgrid Control

Fig. 1 shows the high-level research map of microgrid control from the perspectives of 1) operation mode, 2) function

grouping, 3) timescale, 4) hierarchical structure, 5) communication interface, and 6) control techniques. For each perspective, there are articles providing comprehensive reviews. They are denoted in Fig. 1 for the reader’s reference.

1) *Operation Mode*: A microgrid can operate in either grid-connected (GC) mode or islanded (IS) mode depending on its connectivity to the main grid [31], [32]. In GC mode, the microgrid keeps tracking the phase of the main grid through the phase-locking loop (PLL), and exchanges the mismatched power at the point of common coupling (PCC). In IS mode, the microgrid forms a self-sufficient system based on the local generations. Ref. [33] summarized the strategies for the seamless transition between GC and IS modes.

2) *Function Grouping*: To meet the objectives of the microgrid operation, the 2nd viewpoint is associated with function grouping, which specifically include the microgrid controller and device controller [34]. Grid-level controllers focus on supervisory control functions and grid interactive control functions, and they are more likely to be software-based and applied to the hardware; while device controllers focus on device-level control functions and local-area control functions, and they are more likely to be applied directly on the hardware (devices and assets).

3) *Timescale*: The time scale of microgrid control is tightly related with the control structure. So, it will be discussed in detail in the next discussion about hierarchical structure.

4) *Hierarchical Structure*: The hierarchical control structure is another specific function grouping perspective that clearly sets up the control targets for all the controllers, with which each level controller can work independently within the distinct timescales [11].

The primary controller is responsible for voltage and current control of inverters and automatic power sharing among generations while maintaining V-f stability on a timescale of seconds [35]. The indirect current control is used in the early stages [36], [37], and is later replaced by the direct current control due to its fast response and accurate current control capability [38]. More details can be found in the review paper [39]. Because the primary controller pertains to fast control actions, it predominantly determines the stability of microgrids [2]. Ref. [40] gave an overview of the primary control of microgrids. The secondary controller mitigates the V-f deviation unsolved by the primary controller in the timescale of seconds to minutes. It improves the power quality by generating supplementary signals based on the errors between the measurements and reference values. Ref. [41], [42] performed a review on the secondary control of ac microgrids. The tertiary controller mainly focuses on economic and resilient operations in the timescale of minutes to hours. It adjusts the setting points of the primary and secondary controllers by solving optimal power flow and considering the load side demand response. Some reviews can be found in [43], [44].

5) *Communication Interface*: Depending on the communication interface, the control structure of the microgrid can also be categorized into centralized control, decentralized control, and distributed control [45].

In centralized control, the microgrid control center coordinates the load and generation and responds to all disturbances.




Fig. 1. High-level research map of microgrid control.

It collects and processes all the local information before sending the control signals to each device. The centralized control has the advantage of accurate power-sharing and good transient performance but suffers from the high cost of the communication device and single point failure. In distributed control, each node communicates only with its adjunct nodes. Average-based, consensus-based, and event-triggered distributed algorithms are employed in microgrid control [46]. Distributed control algorithms require the connected communication graph of microgrids. They also have a reduced convergence speed as the network grows [47]. In decentralized control, the control signals are generated based on local measurements. It has the advantage of the plug-and-play capability and is free of communication channel time delay, but it suffers from inaccurate power-sharing and large V-f deviation after disturbances. Ref. [47] conducted a review from the perspective of communication interfaces and summarized some tricks to address their flaws.

6) *Control Techniques*: Both model-based and data-driven control techniques have been utilized in microgrid control. Beginning with the classical linear control theory, advanced model-based control approaches such as non-linear control, optimum control, and model-predictive control (MPC) are then extensively used in microgrids. Ref. [48] summarized the advances and opportunities of employing MPC in microgrids, and [49] reviewed the robust control strategies in microgrids. To address the problems of model uncertainty and unavailability, a variety of data-driven methodologies

such as cutting-edge machine learning (ML) and deep learning (DL) are also employed in microgrid control. Ref. [50] reviewed the application of big data in microgrids, and [51] conducted a survey on DL for microgrid load and DER forecasting. A review of MFRL for microgrid control has yet to be done, which is why it is the main scope of this manuscript.

In summary, MFRL is a promising approach that is worth investigating and being employed in microgrids. As shown in the high-level research map, MFRL doesn't mean to replace the existing control framework, but to complement it, improve it in a data-driven way, and finally work as an integrated part of the microgrid controller.

B. Configuration of Grid-Following and Grid-Forming Inverters

GFL and GFM inverters are no doubt one of the most important units in microgrids [52]. This subsection develops the modularized control blocks to present the bottom-level control details of GFL and GFM inverters. Fig. 2 shows the diagram of the modularized control blocks, with which a GFL or GFM inverter can be configured easily by connecting the modules in series. In addition, it is beneficial to the fusion summary in Section IV because the diagram clearly shows the control details that could couple with MFRL.

1) *M1: Grid \cup Inverter Module*: The 1st module (M1) is named the 'Grid \cup Inverter Module' because it illustrates the




Fig. 2. Modularized control blocks of GFL and GFM inverters.

connection of an inverter to the main grid. As shown in Fig. 2, the dc source, dc-ac inverter, and RLC filter are linked in series, which are then connected to the main grid through the PCC. Here, an average model of an inverter that neglects the switching of pulse-width modulation (PWM) is often employed for the control system design. All the high-level controllers work together to generate the reference terminal voltage $e_{abc-ref}$ for PWM.

2) *M2: Terminal Voltage-Ref Module*: The 2nd module (M2) is named the ‘Terminal Voltage-ref Module’ since it directly generates the reference terminal voltage. The control model is formulated using Kirchhoff’s voltage law (KVL) from e_{abc} to u_{abc} and conducting Park transformation. Then, after implementing proportional-integral (PI) controllers, the physical model and control transfer function in dq framework are shown in (1) and (2), respectively.

$$L_f \begin{bmatrix} \frac{di_d}{dt} \\ \frac{di_q}{dt} \end{bmatrix} + wL_f \begin{bmatrix} -i_q \\ i_d \end{bmatrix} = \begin{bmatrix} e_d \\ e_q \end{bmatrix} - \begin{bmatrix} u_d \\ u_q \end{bmatrix} \quad (1)$$

$$\begin{bmatrix} e_d \\ e_q \end{bmatrix} = \begin{bmatrix} u_d \\ u_q \end{bmatrix} + wL_f \begin{bmatrix} -i_q \\ i_d \end{bmatrix} + \begin{bmatrix} k_{pid} + \frac{k_{iud}}{s} & 0 \\ 0 & k_{piq} + \frac{k_{iiq}}{s} \end{bmatrix} \left(\begin{bmatrix} i_{dref} \\ i_{qref} \end{bmatrix} - \begin{bmatrix} i_d \\ i_q \end{bmatrix} \right) \quad (2)$$

3) *M3: Current-Ref Module*: The 3rd module (M3) is named the ‘Current-ref Module’ since it generates the reference current $[i_{dref}, i_{qref}]$ for M2. For a GFL inverter, $[i_{dref}, i_{qref}]$ are regulated based on the error between the actual output and the reference value. Eqs. (3)-(4) show the transfer function of M3 using PI controllers, where two low-pass filters are used to filter measured power output.

$$\begin{bmatrix} i_{dref} \\ i_{qref} \end{bmatrix} = \begin{bmatrix} k_{pP} + \frac{k_{iP}}{s} & 0 \\ 0 & k_{pQ} + \frac{k_{iQ}}{s} \end{bmatrix} \begin{bmatrix} P - P_{ref} \\ Q - Q_{ref} \end{bmatrix} \quad (3)$$

$$\begin{bmatrix} P \\ Q \end{bmatrix} = \begin{bmatrix} \frac{1}{T_{fP}s+1} & 0 \\ 0 & \frac{1}{T_{fQ}s+1} \end{bmatrix} \begin{bmatrix} P_{mes} \\ Q_{mes} \end{bmatrix} \quad (4)$$

For a GFM inverter, its physical model is formulated using Kirchhoff’s current law (KCL) at point u_{abc} . After Park transformation and PI controller integration, the algebraic equation and control transfer function in dq framework are shown in (5) and (6), respectively.

$$C_f \begin{bmatrix} \frac{du_d}{dt} \\ \frac{du_q}{dt} \end{bmatrix} + wC_f \begin{bmatrix} -u_q \\ u_d \end{bmatrix} = \begin{bmatrix} i_d \\ i_q \end{bmatrix} - \begin{bmatrix} i_{gd} \\ i_{gq} \end{bmatrix} \quad (5)$$

$$\begin{bmatrix} i_{dref} \\ i_{qref} \end{bmatrix} = \begin{bmatrix} i_{gd} \\ i_{gq} \end{bmatrix} + wC_f \begin{bmatrix} -u_q \\ u_d \end{bmatrix} + \begin{bmatrix} k_{pud} + \frac{k_{iud}}{s} & 0 \\ 0 & k_{puq} + \frac{k_{iiq}}{s} \end{bmatrix} \left(\begin{bmatrix} u_{dref} \\ u_{qref} \end{bmatrix} - \begin{bmatrix} u_d \\ u_q \end{bmatrix} \right) \quad (6)$$

4) *M4: Power \cap Voltage Module*: The 4th module (M4) is named the ‘Power \cap Voltage Module’ which indicates the fundamental difference between GFL and GFM inverters. A GFL inverter is controlled as a current source and requires a power reference as an input, while a GFM inverter is controlled as a voltage source and needs a voltage reference as an input [39]. Another big difference is that a GFL inverter needs a PLL to track the phase of the main grid while a GFM inverter is self-synchronized [53]. Droop control is the most widely used control method in microgrids. It takes advantage of the coupling between power generation and the grid V-f [54]. Typically, an inductive microgrid employs the $P-f$ and $Q-V$ droop curves, while resistive microgrids uses the reverse $P-V$ and $Q-f$ droop curves. The M4 plotted in Fig. 2 shows the control blocks for an inductive microgrid, and their control models are shown below.

- Droop-controlled GFL inverter

$$\begin{bmatrix} P_{ref} \\ Q_{ref} \end{bmatrix} = \begin{bmatrix} k_f & 0 \\ 0 & k_v \end{bmatrix} \left(\begin{bmatrix} w_0 \\ U_0 \end{bmatrix} - \begin{bmatrix} w_{mes} \\ U_{mes} \end{bmatrix} \right) + \begin{bmatrix} P_0 \\ Q_0 \end{bmatrix} \quad (7)$$

- Droop-controlled GFM inverter

$$\begin{bmatrix} w_{ref} \\ u_{dref} \end{bmatrix} = \begin{bmatrix} \frac{1}{k_f} & 0 \\ 0 & \frac{1}{k_v} \end{bmatrix} \left(\begin{bmatrix} P_0 \\ Q_0 \end{bmatrix} - \begin{bmatrix} P_{mes} \\ Q_{mes} \end{bmatrix} \right) + \begin{bmatrix} w_0 \\ V_0 \end{bmatrix} \quad (8)$$

To provide more inertia support to microgrids leveraging DERs, the virtual synchronous generator (VSG) control method is proposed to emulate the behavior of synchronous generators [55]. Mathematically speaking, the VSG belongs to proportional-differential control. Below is the transfer function of the GFL and GFM inverters implementing the VSG.

- VSG-controlled GFL inverter

$$\begin{bmatrix} P_{ref} \\ Q_{ref} \end{bmatrix} = \begin{bmatrix} D + Ks & 0 \\ 0 & k_v \end{bmatrix} \times \left(\begin{bmatrix} w_0 \\ U_0 \end{bmatrix} - \begin{bmatrix} w_{mes} \\ U_{mes} \end{bmatrix} \right) + \begin{bmatrix} P_0 \\ Q_0 \end{bmatrix} \quad (9)$$

- VSG-controlled GFM inverter

$$\begin{bmatrix} w_{ref} \\ u_{dref} \end{bmatrix} = \begin{bmatrix} \frac{1}{J_{Ps}} & 0 \\ 0 & \frac{1}{J_{Qs}} \end{bmatrix} \left\{ \left(\begin{bmatrix} P_{ref} \\ Q_{dref} \end{bmatrix} - \begin{bmatrix} P_{mes} \\ Q_{mes} \end{bmatrix} \right) - \begin{bmatrix} D\Delta w \\ 0 \end{bmatrix} \right\} + \begin{bmatrix} w_0 \\ U_0 \end{bmatrix} \quad (10)$$

Readers are encouraged to check Refs. [56], [57] for some modified VSG and droop control techniques that provide more effective inertia support to microgrids.

5) *M5: Auxiliary Service \cup Optimization Module*: Microgrids exploiting M1-M4 can withstand normal disturbances such as load changes and plug-and-play generations. Then, M5 participates in grid optimization and provides auxiliary services, i.e., optimized active and reactive power sharing, demand-side management, and V-f support [58]. In order for more economic energy management, M5 also calculates the steady-state setting points such as (P_0, Q_0) by solving optimal power flow [59]. On the other hand, it generates the supplementary signals for controller parameters and outputs [60] according to the targets of auxiliary service. Review papers regarding M5 can be seen in [61], [62].

C. Motivation for MFRL

1) *Challenges in the Existing Control Framework*: The high-level research map and modularized control blocks clearly show how existing microgrids are controlled. However, the evolution of microgrids brings more challenges to the existing control framework. The challenges are five-fold: i). The penetration of DERs results in higher uncertainties. Although some robust and stochastic techniques have been employed to address the emerging uncertainties, they are somehow conservative and the probability distribution function still needs to be accurately estimated. ii). It is difficult to model each element of microgrids in detail, i.e., customer behavior. The information that is difficult to model is critical for energy management in M5. iii). Some system parameters are not always accessible; even if accessible, they are not necessarily accurate. iv). Microgrid dynamics are becoming faster because more and more inverter-based resources participate in grid services by adaptively changing their control modes and control parameters. Then, the existing controllers may not be valid anymore. v). Smart grids call for autonomous microgrids, with which engineers and grid operators are free from parameter tuning for modules in Fig. 2. Even for other model-free controllers, they still need elaborate tuning for hyper-parameters, i.e., the membership functions of the fuzzy logic controller and the coefficients of the adaption law.

2) *Why MFRL?*: Microgrid operators have access to massive data sampled by phasor measurement units (PMUs) and advanced metering infrastructures (AMIs) now [63]. It opens the possibility for data-driven control. MFRL is an advanced decision-making technique with goal-oriented, data-driven, and model-free characteristics [64]. With the help of MFRL, the uncertainties of the model and parameters may be mitigated through repeated interaction between the environment and the RL agent. It is also beneficial to the autonomous operation of microgrids because the RL agent can actively update its policy based on the microgrid dynamics.

To better fuse MFRL with the existing microgrid control framework, it is necessary to first know the capabilities of each MFRL algorithm, and then choose the proper algorithms in real applications. Thus, the following sections introduce the map of MFRL, the features of main stream MFRL algorithms, and how MFRL can be incorporated into the existing microgrid control framework.

III. MODEL-FREE REINFORCEMENT LEARNING

This section first gives a brief introduction to RL and then summarizes the methodology of MFRL.

A. Formulation of RL

RL is a basic ML paradigm formulated as an MDP. As shown in Fig. 3(a), the environment defines the state space \mathcal{S} and the agent holds the action space \mathcal{A} . The agent keeps interacting with the environment to update its policy π that maps the environment states to actions. In each iteration, the agent chooses action $a_t \in \mathcal{A}$ according to π . Then, the environment generates the next state according to its intrinsic transition probability $\mathbb{P}(s_{t+1} | s_t, a_t) : \mathcal{S} \times \mathcal{A} \rightarrow \Delta(\mathcal{S})$ and feeds back




Fig. 3. The framework and map of MFRL. (a) agent-environment interaction in an MDP. (b) methodology.

the instant reward $r(s_t, a_t)$ to the agent. The iteration is repeated until the agent finds the optimal policy π^* as follows.

$$\pi^* \in \arg \max_{\pi} J(\pi) = \mathbb{E}_{\pi} \sum_{t=1}^{\infty} \gamma^t r(s_t, a_t) \quad (11)$$

where γ is the discounting factor and $J(\pi)$ is the infinite horizon discounted reward. The optimal policy guarantees the maximum accumulated reward obtained from the environment.

In MFRL, \mathcal{A} and \mathcal{S} can be either continuous or discrete. For the sake of illustration, this paper uses discrete notation to introduce the methodology.

B. Methodology of MFRL

Fig. 3(b) shows the mainstream MFRL methodology. They are categorized into value-based and policy-based algorithms.

1) **Value-Based Algorithms**: The value-based methods learn the Q -function that estimates the Q -value of state-action pairs $(s, a) \in \mathcal{S} \times \mathcal{A}$. The Q -function is denoted as Q_{π} , based on which the agent can choose the optimal actions with the maximum Q -value. According to the Bellman equation,

$$Q_{\pi}(s_{t+1}, a_{t+1}) = r(s_t, a_t) + \gamma E_{s_{t+1}, a_{t+1}} Q_{\pi}(s_{t+1}, a_{t+1}) \quad (12)$$

Through temporal-difference learning, Q_{π} can finally converge to its true value under mild assumptions [65].

$$Q_{\pi}(s_t, a_t) = Q_{\pi}(s_t, a_t) + \alpha \left[r_t + \gamma \max_{a_{t+1} \in \mathcal{A}} Q_{\pi}(s_{t+1}, a_{t+1}) - Q_{\pi}(s_t, a_t) \right] \quad (13)$$

The approximated Q_{π} was first recorded in a Q -table [66]. Considering the table's inefficiency, the deep Q -learning network (DQN) [67] replaced the Q -table with a deep artificial neural network (ANN), which has a strong fitting capability that maps the states to Q -value with less memory. Then, the DQN was further improved using the following tricks [68]:

- (Prioritized) Reply Buffer enhances the training efficiency.
- Double Network relieves the overestimation of Q -value.
- Dueling Network improves the performance in high-dimensional action space.

Later, a distributional DQN [69] and a quantile regression DQN [70] were proposed using stochastic policy and distributed training, and they were combined as 'Rainbow DQN' by David Silver [71] in 2017.

2) **Policy-Based Algorithms**: Policy gradient methods directly learn the parameterized policy based on feedback from the environment. Before diving into policy gradient algorithms, it is necessary to introduce the actor-critic (AC) structure. The AC structure has two ANN models that optionally share parameters: i) Critic updates the parameters of value functions; ii) Actor updates the policy parameters under the guidance of the critic. Under the AC structure, policy function can be either stochastic or deterministic. The stochastic policy is modeled as a probability distribution: $a \sim \pi_{\theta}(a | s)$, while the deterministic policy is modeled as a deterministic decision: $a = \pi_{\theta}(s)$. They classify the policy-gradient methods.

a) **Stochastic Policy**: As for stochastic policy $a \sim \pi_{\theta}(a | s)$, the gradient of the expected reward to policy parameters is calculated according to policy gradient theorem [72] as follows

$$\nabla J(\theta) = \sum_{s \in \mathcal{S}} \mu_{\theta}(s) \sum_{a \in \mathcal{A}} \pi_{\theta}(a | s) Q_{\pi_{\theta}}(s, a) \nabla_{\theta} \ln \pi_{\theta}(a | s) \quad (14)$$

where $\mu_{\theta}(\mathcal{S}) \in \Delta(\mathcal{S})$ is the state distribution. Then, the policy is updated using the gradient ascent method

$$\theta_{t+1} = \theta_t + \eta \nabla J(\theta_t) \quad (15)$$

where η is the learning rate. It is necessary to avoid large updating of step size in each iteration since the policy gradient readily falls into a local maximum. To make the policy gradient training more stable, trust region policy optimization (TRPO) added a Kullback-Leibler (KL) divergence constraint to the process of policy updating [73]. It solves the optimization problem as follows

$$\begin{aligned} \max_{\theta} J(\theta) &= \mathbb{E} \left[\frac{\pi'_{\theta}(a | s)}{\pi_{\theta}(a | s)} \hat{A}_{\theta}(a | s) \right] \\ \text{s.t. } &\mathbb{E} [D_{KL}(\pi'_{\theta} \| \pi_{\theta})] \leq \delta \end{aligned} \quad (16)$$

where π'_{θ} is the new policy; D_{KL} is the KL-divergence.

Considering the complexity of measuring D_{KL} in each update, proximal policy optimization (PPO) was developed to accelerate the training [74]. PPO uses a clipped surrogate objective while retaining similar performance as follows

$$\max_{\theta} J(\theta) = \mathbb{E} \left\{ \min \left[\frac{\pi_{\theta}'(a | s)}{\pi_{\theta}(a | s)} \hat{A}_{\theta}(a | s) \right. \right. \\ \left. \left. \text{clip} \left(\frac{\pi_{\theta}'(a | s)}{\pi_{\theta}(a | s)}, 1 - \varepsilon, 1 + \varepsilon \right) \hat{A}_{\theta}(a | s) \right] \right\} \quad (17)$$

In PPO, the actor network and critic network share the same learned features, and this may result in conflicts between competing objectives and simultaneous training. Hence, a phasic policy gradient (PPG) separates the training phased for actor and critic networks [75], which leads to a significant improvement in sampling efficiency. Other improved versions of the AC structure include advantage actor-critic (A2C), asynchronous advantage actor-critic (A3C), and soft actor-critic (SAC). A2C and A3C both enable parallel training using multiple actors, but the actors of A2C work synchronously, and those of A3C work asynchronously [76]. SAC improves the exploration of agents incorporating policy entropy [77].

b) *Deterministic Policy*: The gradient of deterministic policy $a = \pi_{\theta}(s)$ is expressed as

$$\nabla J(\theta) = \mathbb{E}_{s \sim \mu_{\theta}} \nabla_a Q_{\pi_{\theta}}(s, a) \Big|_{a=\pi_{\theta}(s)} \nabla_{\theta} \pi_{\theta}(s) \quad (18)$$

The deterministic policy gradient (DPG) method firstly used deterministic policy [78]. Then, the deep deterministic policy gradient (DDPG) was developed by combining the DPG and DQN [79]. The DDPG extends the discrete action space of the DQN to continuous space while learning a deterministic policy. Later, the twin delayed deep deterministic (TD3) policy gradient applied three tricks, i.e., clipped network, delayed update of critic network, and target policy smoothing to prevent the overestimation of Q -value in the DDPG.

3) *Summary*: The DQN, DDPG, and A3C are three basic paradigms of MFRL representing value-based methods, deterministic policy methods, and stochastic policy methods. Their upgraded versions, the Rainbow DQN, TD3, and PPG, SAC represent the state-of-the-art of each paradigm, which are the best choices for fusing MFRL with the existing microgrid control framework. Moreover, the value-based methods such as DQN are more suitable for discrete control tasks like transformer tap and switch on/off control, while the policy-based methods like TD3 are more suitable for continuous tasks such as active power and reactive power reference generation.

IV. FUSION OF MODEL-FREE REINFORCEMENT LEARNING WITH MICROGRID CONTROL

Section II and Section III introduce the existing microgrid control framework and the MFRL, separately. This section further the fusion details, including the application guidelines and the challenges and insights of using MFRL in microgrid control.

A. Application Guideline

1) *Problem Formulation*: Microgrid control is intrinsic to an infinite MDP that MFRL can solve. Ref. [80] answered the question of ‘How,’ that is, ‘How to formulate a control problem that can be solved by MFRL?’, which includes four steps: i). Determine the environment, state space \mathcal{S} , and action

space \mathcal{A} ; ii) Design reward function \mathcal{R} according to control targets; iii). Select proper learning algorithm; iv). Train agent and validate the learned policy. The four steps are exemplified below based on two specific application scenarios, frequency regulation and voltage regulation.

i) Formulation of frequency regulation: Eqs. (19)-(21) show the general configuration of a MFRL agent for frequency regulation in microgrids. The agent has unique action space when fusing with different modules in Fig. 2.

$$\mathcal{S}_f := \left[(w_i)_{i \in \mathcal{N}}, (P_{ij}, Q_{ij})_{ij \in \mathcal{E}} \right] \quad (19)$$

$$\mathcal{A}_f = \begin{cases} \text{M2} : \left[(e_{abc,i})_{i \in \mathcal{I}} \right] \\ \text{M3} : \left[(i_{d,i}, i_{q,i})_{i \in \mathcal{I}} \right] \\ \text{M4} : \left[(P_{ref,i}, Q_{ref,i})_{i \in \mathcal{I}_{GFL}}, \right. \\ \quad \left. (w_{ref,i}, u_{dref,i})_{i \in \mathcal{I}_{GFM}} \right] \\ \text{M5} : \left[(P_{0,i}, Q_{0,i}, \Delta x_i)_{i \in \mathcal{I}} \right] \end{cases} \quad (20)$$

$$\mathcal{R}_f(t) = - \sum_{i \in \mathcal{N}} [w_i(t) - w_0]^2 \quad (21)$$

where w_i is frequency at each bus i ; (P_{ij}, Q_{ij}) is the power flow over line from bus i to bus j ; M2-M5 are the modules summarized in Fig. 2; \mathcal{I} is the inverter set; \mathcal{I}_{GFL} and \mathcal{I}_{GFM} are the set of GFL inverters and GFM inverters, respectively. Since the control target is to maintain frequency, the deviation of frequency is designed as reward function.

ii) Formulation of voltage regulation: Eqs. (22)-(24) show the general configuration of a MFRL agent for frequency regulation in microgrids.

$$\mathcal{S}_v := \left[(v_i)_{i \in \mathcal{N}}, (P_{ij}, Q_{ij})_{ij \in \mathcal{E}}, (\tau_i)_{i \in \mathcal{T}} \right] \quad (22)$$

$$\mathcal{A}_v = \begin{cases} \text{M2} : \left[(e_{abc,i})_{i \in \mathcal{I}} \right] \\ \text{M3} : \left[(i_{d,i}, i_{q,i})_{i \in \mathcal{I}} \right] \\ \text{M4} : \left[(P_{ref,i}, Q_{ref,i})_{i \in \mathcal{I}_{GFL}}, \right. \\ \quad \left. (w_{ref,i}, u_{dref,i})_{i \in \mathcal{I}_{GFM}} \right] \\ \text{M5} : \left[(P_{0,i}, Q_{0,i}, \Delta x_i)_{i \in \mathcal{I}}, (\tau_i)_{i \in \mathcal{T}} \right] \end{cases} \quad (23)$$

$$\mathcal{R}_v(t) = - \sum_{i \in \mathcal{N}} [v_i(t) - v_0]^2 \quad (24)$$

where v_i is the voltage magnitude of bus i , and τ_i is the tap positions of the on-load tap changers (OLTPs) of transformers. Compared with frequency regulation, the agent has distinct action of OLTPs in M5 for voltage regulation.

After selecting \mathcal{S} , \mathcal{A} , and \mathcal{R} , the mainstream MFRL algorithms are selected to update the policy of the agent. Note that the selected algorithms should be applicable to the application scenarios. For example, the discrete algorithm in Fig. 3(b) is better for discrete control actions like OLTPs. In addition, the above formulations give a general form of configuring an MFRL agent for microgrid control, and they can be modified according to customized control tasks.

In addition to problem formulation, there are another two fundamental questions regarding ‘What’ that remain to be answered. They are

- Q1: What kinds of tasks is MFRL suitable for?
- Q2: How can MFRL be fused with the existing microgrid control framework?

The following two subsections tries to answer these two questions based on the state-of-the-art of MFRL. The answers can serve as the application guideline for adopting MFRL in microgrids.

2) *What Kinds of Tasks Is MFRL Suitable For?:* In general, MFRL is suitable for tasks with the following four features:

i) Relatively unchanged environment. Policy learned by RL agents reflects the physical law in the training environments, which fundamentally determines the state transition probability. As shown in the diagram in Fig. 3(a), environment generates rewards based on $\mathbb{P}(s_{t+1} | s_t, a_t) : \mathcal{S} \times \mathcal{A} \rightarrow \Delta(\mathcal{S})$ and feed the rewards to RL agent for policy updating. A new environment has distinct state transition probability function, which may have conflicts with the buffer data and trained policy. Thus, the working environment should not differ too much from the training environment. That's why in Tab. I, the training microgrids and validation microgrids usually have fixed topology and predefined disturbances.

ii) Clear control target. Clear control targets facilitate the design of reward functions. The objective function in the optimization problem, optimal control, and MPC can be directly transformed to a reward function. With the function grouping and hierarchical structure in Fig. 1, the specific control targets can be briefly categorized into frequency regulation, voltage regulation equation, and economic benefits. Then, the voltage deviation [81], frequency deviation [87] and energy management cost/revenue [83], [84] are transformed into reward functions in (21) and (24). Crucially, a well-designed reward function gives the MFRL agent the best guide to learn the optimal policy.

iii) Available data. Environmental data must be accessible if the agent interacts with a real system. Also, the real environment should tolerate improper actions for exploration. If the environment is a simulator, the simulation should run quickly to allow for thousands of repetitions. For example, a fast a simulator and a real tokamak vessel were developed for training and validation in [30].

iv) Acceptable control complexity. 'Acceptable' means that the control complexity should be neither too low nor too high. For each perspective summarized in the high-level research map, there is no research trying to replace all the controllers. Most of the research just focused on a specific task that a model-based controller cannot handle but MFRL can, because there is no need to replace a simple model-based controller that has good performance and it is unrealistic to let AI directly control the whole microgrid for now.

3) *How Can MFRL Be Fused With the Existing Microgrid Control Framework?:* MFRL is essentially a useful tool that serves microgrid control. It follows microgrid control targets when fused with the existing control framework. In general, there are three ways of fusing as follows.

i). Model identification and parameter tuning. MFRL assists in identifying the uncertain models of the grid components accurately. Also, it can address the uncertainty and unavailability of model parameters and release the grid operators from complex and time-consuming parameter tuning, especially tuning a large model with many parameters.




Fig. 4. Microgrid testbeds [34] and MFRL environment.

ii). Supplementary signal generation. MFRL can generate the supplementary control signals for model-based controllers, with which the current controllers can be made more robust and deal with complicated control tasks.

iii). Controller substitution. MFRL can completely replace the existing model-based controllers if they are no longer effective. It needs fewer inputs but has better performance than model-based controllers owing to the ANN's strong fitting capability.

In general, the application guide is summarized based on the existing microgrid control research that employ MFRL. The detailed literature review will be performed in the next subsection.

B. Literature Review

Sorted in the way of fusing, Table I summarizes the literature adopting MFRL in microgrids, where the key features are listed in the last column. In general, MFRL has fused with the optimization and control tasks in microgrids. Most research has tried to replace the existing model-based controllers with MFRL agents. In addition, more researchers focus on optimization problems that have clear targets. The objective functions are directly transformed or incorporated into the reward function.

C. Challenges and Insights

Although many researchers have been investigating the applications of MFRL in microgrid control, there is still a clear gap between theory (simulation) and practice (real microgrid operation). The main concerns are the aspects of the environment, scalability, generalization, security, and stability. This subsection summarizes these challenges and gives some insights on how to tackle them.

1) Environment:

• Challenges: As shown in Fig. 4, the conventional model-based microgrid controllers have several types of tests before implementation, i.e., simulation, controller hardware in the loop (HIL) test, power HIL test, subscale system test, and full system test. They are the options for the MFRL environment.

TABLE I
LITERATURE SUMMARY OF IMPLEMENTING MFRL IN MICROGRIDS

Ref.	Year	Topic	Algorithm	Way of fusing	Environment	Key features
[82]	2020	Converter voltage stability	PPO	Parameter tuning for M4	dSPACE MicroLabBox	1) Adaptively tune the feedback gains of the ultra-local model; 2) Mitigate the stability issues caused by constant power loads
[86]	2022	Cyber attack	DQN, Multi-agent DDPG	Model identification for M2-M4	MATLAB/Simulink, dSPACE MicroLabBox DS1202	1) RL agent automatically discover the vulnerable spots and generate coordinated destabilizing false data attacks; 2) Enhanced agent with a sniffing feature to enable maintaining the stealthy attacks under connection failure.
[85]	2021	Transient stability	SAC	Model identification for M4	Numerical simulator	1) Consider multiple events that result in transient stability simultaneously; 2) Test learned policy in new events
[89]	2020	Microgrid Penetration Test	A3C	Supplementary signal generation for M5	Numerical simulator	1) Perform Penetration Testing for microgrids 2) RL agent uncovers the malicious input that can compromise the effectiveness of the controller
[88]	2021	dc-dc buck converter control	DDPG	Supplementary signal generation for M4	dSPACE MicroLabBox and DS1302 I/O board	1) Design an intelligent PI controller based on sliding mode observer to mitigate instability; 2) RL agent generates the auxiliary signals to reduce the error of observer
[92]	2021	Secondary frequency control	DDPG	Supplementary signal generation for M5	Matlab and dSPACE 1202 board	1) Consider Type-II fuzzy system; 2) Generate supplementary signals for PI-based secondary controllers
[90]	2022	Secondary frequency control	A2C	Supplementary signal generation for M4	Discrete-time ODE model in numerical simulator	1) Achieve frequency synchronization within an ultimate bound given dominantly resistive and/or inductive line and load impedances; 2) A feedback control is formulated based on the unknown dynamics, using Lyapunov theory.
[91]	2021	Mode transition	Q-learning	Supplementary signal generation for M4	Numerical simulator	1) RL agent generates voltage angle and magnitude adjustments; 2) Enables bulk power grid restoration by using microgrids' black start capability.
[93]	2019	Energy management	Q-learning	Controller substitution in M5	Matlab and Python	1) Perform privacy-preserved response learning for multi-microgrids; 2) Implement Monte Carol method for decision making
[94]	2019	Battery SOC control	DDPG	Controller substitution in M4	Numerical simulator	1) Perform supervised pre-training for critic-network based on control cost; 2) Perform pre-training for actor-network based on the output of PI controllers
[95]	2019	Energy storage system control	Q-learning	Controller substitution in M4 and M5	Matlab-Simulink Simscape toolbox	1) Optimize the charging and discharging profile to suppress the disturbance caused by integrating a new hybrid energy system; 2) One network estimates the unknown system dynamics and the other solves the optimal policy
[96]	2020	Emergency control	DQN	Controller substitution in M5	InterPSS in java and OpenAI in python	1) Train RL agent under the circumstance of predefined topology and random short-circuit faults; 2) Use hybrid simulation with java and python
[97]	2021	Islanding transition control	Q-learning	Controller substitution in M3-M5	Matlab-Simulink	1) Update specific values or parameters in reinforcement learning with artificial emotion; 2) Implement load shedding to reduce the impacts of intentional islanding
[98]	2021	Energy storage system control	DDQN	Controller substitution in M4	Numerical simulator (TensorFlow and GUROBI)	1) Improve robustness with prioritized replay policy based on sum-tree; 2) RL agent directly outputs actions without solving an optimization problem
[4]	2022	Peer-to-peer energy trading	Multi-agent TD3	Controller substitution in M5	Numerical simulator	1) Consider both external peer-to-peer energy trading and internal energy conversion; 2) The high-dimensional decision-making problem is solved by multi-agent TD3 under the resolution of hours
[81]	2021	Secondary voltage control	Multi-agent A2C	Controller substitution in M	Numerical simulator	1) A high-fidelity powergrid simulation platform 'PGSim' is developed as environment; 2) Enhance the scalability with spatial discount factor to reduce the effect from remote agents.
[83]	2022	P2P trading	Multi-agent DDPG	Controller substitution in M5	Numerical simulator	1) Incentivize energy trading with distribution network tariffs to satisfy the physical constraints; 2) Do simulations based on real-world trading data sets.
[99]	2022	Energy management	Trust region PPO	Controller substitution in M5	Numerical simulator	1) The distribution system operator (DSO) is viewed as a RL agent without knowing user information for privacy protection; 2) Integrate a differentiable trust region layer to improve the robustness of the policy updating.
[100]	2021	Online economic dispatch	Hierarchical Q-learning	Controller substitution in M5	Numerical simulator	1) Offers a subtle blend of immediate and future rewards to guarantee a long-term performance; 2) Integrate domain knowledge to narrow down learning space to a feasible region and avoids violations.

Existing literature suggests offline training in the numerical simulator and online implementation in real systems [95] because the RL agent requires sufficient exploration during training which is unrealistic in HIL or real systems.

That's why early RL was mainly used in video games, where the simulator could perfectly emulate the working environments. Among the current power testbed types, simulation has the highest coverage of test scenarios but the

least fidelity, which is the major concern of employing MFRL. Even if the agent learned a good policy in a numerical simulator, it may not function effectively in a real microgrid.

- **Insights:** As for numerical simulators, they are on the way to developing a more accurate and faster toolbox capable of serving as a high-fidelity MFRL environment. Improved power system modeling [101], [102] and more efficient numerical simulation techniques, such as the hybrid symbolic-numeric framework [103], are currently being developed. Further, it would be better to develop a standardized and customized training environment that assists in setting up the interface with power simulators such as PSCAD, PSSE, and MATLAB-Simulink, just like “Gym” in the field of deep RL. The standardized environment can also serve as a baseline for algorithm tests and comparisons. On the other hand, it is a good way to design a HIL test system that is equipped with specialized protection and can tolerate random exploration to some degree. In this way, the HIL test system may work as an environment that closely resembles an actual microgrid. Moreover, MFRL agent can learn from historical data. To improve the learning efficiency and address the problem of real-data insufficiency, some advanced techniques have been developed. For example, i) long-tail learning [104] can learn effectively on biased data set; ii). deep active learning [105] can also be used to more efficiently label disturbance data.

2) Scalability:

- **Challenges:** MFRL suffers from the curse of dimensionality like some model-based controllers. The expansion of state space and action space will result in an exponential increase in control complexity, thereby increasing the difficulty of exploration and training. Existing MFRL research on microgrid control mainly focuses on some small-scale problems [98] and utilizes ANN with a few layers. To promote the application of MFRL in microgrid control, it is necessary to improve its scalability.

- **Insights:** On the one hand, it is an effective way to reduce control complexity by integrating domain knowledge into problem formulation. For example, [106] narrowed down the learning space and avoided baseline violations based on the generation constraints. On the other hand, it would be better to increase the capability of existing MFRL models by: i). increasing the exploration efficiency by designing guided exploration strategies like evolutionary RL [107]; ii). increasing the fitting capability of ANN through the modern design of network structures, i.e., sequential-to-sequential networks and transformers [108]; iii). increasing the training efficiency through distributed techniques like federated learning [109] and edge computing [110]. All of these methods can help relieve the pressure on training and make MFRL more scalable for microgrid control.

3) Generalization:

- **Challenges:** Similar to DL, MFRL was accused of “inability of generalization” because a well-trained agent does not function effectively in a changing environment [111]. Even in an unchanged environment, the diversity of disturbances may also distort the agent. In microgrid control, it is difficult to

cover all the disturbances during the training, which is critical on the condition that RL agents replace the existing controllers.

- **Insights:** Firstly, rich training scenarios benefit the generalization of MFRL. For example, [112] addressed the uncertainty of Volt-Var control in active distribution systems by generating a bunch of offline training scenarios. It is also a good way to employ robust RL that can tolerate the uncertainty of the environment [113]. Further, transfer learning can also enhance the MFRL’s generalization capability, which has proven to be effective in the field of DL.

4) Security:

- **Challenges:** Security is referred to as static security in this paper, meaning that system state should respect the static physical constraints to avoid damaging the device. In microgrids, these constraints can be thermal limit constraints and control signal constraints decided by the physical capability of microgrid components. They are usually explicit and known according to microgrid device manufacture, and there are IEEE Standards setting the secure operational range of voltage and frequency. However, due to the non-interpretability of ANN, the learned policy cannot always guarantee each variable respect the constraints. Furthermore, it is also a problem to guarantee secure exploration in a HIL or real system. In the future, MFRL agents may be trained in a HIL microgrid to overcome the shortcomings of numerical simulators, where the exploration cannot violate the physical constraints of the HIL or real system for sure.

- **Insights:** Through constrained RL [28], [114] and safe RL [115], [116], the actions of RL agents can be projected to a safety region and thus always respect the physical operational constraints. In addition, physics-constrained and physics-informed deep learning [117] is also under development and can be integrated into MFRL to address security concerns. In physics-constrained deep learning, a “safety layer” is often leveraged to maintain constraint satisfaction under different physics knowledge, while physics-informed learning embeds the knowledge of physical laws that govern by partial differential equations into training.

5) Stability:

- **Challenges:** Stability is referred to as dynamic stability under a disturbance. According to the definition in [118], the stability is the ability of an electric power system, for a given initial operating condition, to regain a state of operating equilibrium after being subjected to a physical disturbance, with most system variables bounded so that practically the entire system remains intact. Model-based microgrid controllers must pass the stability test through eigenvalue analysis or the Lyapunov function validation before implementation. However, the employment of MFRL challenges the model-based criteria because the uninterpretable RL agents dramatically change the closed-loop dynamics of microgrids.

- **Insights:** Integrating domain knowledge is the best way to guarantee microgrid stability for now. As for the first two fusing approaches, i) model identification and parameter tuning and ii) supplementary signal generation, model-based stability criteria can still be used to verify the system stability because the MFRL agent doesn’t break down closed-loop

systems. MFRL complements the model-based approaches and improves them in a data-driven way. The supplementary signals generated by the MFRL agent can be viewed as hyper-parameters. Through techniques like semi-definite programming (SDP), linear matrix inequality (LMI), and sum-of-square programming [119], the security range of these hyper-parameters can be obtained to guarantee dynamic stability [120]. As for the third way of fusion, the complete controller substitution, MFRL agents dramatically change the closed-loop dynamics and make the system difficult to model. To address the stability issues in this condition, this paper gives three potential solutions. i). enrich the training data and training scenarios. The learned policies basically reflect the state transition of the environment. If the training data set has covered sufficient instability scenarios, the corresponding punishment reward can help RL agents avoid unstable actions. ii). use a physics-informed approach by integrating model-based stability criteria into MFRL training. For example, the Lyapunov function [121] and the Gaussian process estimation [116] can be used to generate stability criteria for MFRL training, and [122] proposed a Lyapunov-regularized RL for transmission system transient stability. iii). perform policy stability validation through time-domain simulation (TDS). TDS has been widely used in power systems to validate the stability of nonlinear components or modules. It can also help validate the stability of the inexplicable RL policy.

V. CONCLUSION

Model-based controllers are still the foundation of existing microgrid control systems. However, the emerging challenges caused by the uncertainty of DERs and extreme weather call for advanced control techniques. As a model-free and data-driven approach, MFRL opens the possibility of non-linear, high-dimensional, and high-complex microgrid control. It may contribute to a huge upgrade of the existing control framework.

Against this background, this paper firstly performs a comprehensive review of the current microgrid control framework and then summarizes the applications of MFRL. In general, there are three ways of fusing MFRL with the existing model-based controllers, including i). model identification and parameter tuning, ii). supplementary signal generation, and iii). controller substitution. For now, there is still an obvious gap between the theory (simulation) and its practical application. The challenges are mainly categorized into environment, scalability, generalization, security, and stability. With the rapidly developed techniques in the fields of both power and artificial intelligence, the author believes the challenges summarized in this paper will finally be overcome. Someday in the future, the MFRL can perfectly fuse with the existing microgrid control framework.

REFERENCES

- [1] D. E. Olivares et al., "Trends in microgrid control," *IEEE Trans. Smart Grid*, vol. 5, no. 4, pp. 1905–1919, Jul. 2014.
- [2] M. Farrokhhabadi et al., "Microgrid stability definitions, analysis, and examples," *IEEE Trans. Power Syst.*, vol. 35, no. 1, pp. 13–29, Jan. 2019.
- [3] J. Liu, Y. Miura, H. Bevrani, and T. Ise, "Enhanced virtual synchronous generator control for parallel inverters in microgrids," *IEEE Trans. Smart Grid*, vol. 8, no. 5, pp. 2268–2277, Sep. 2017.
- [4] T. Chen, S. Bu, X. Liu, J. Kang, F. R. Yu, and Z. Han, "Peer-to-peer energy trading and energy conversion in interconnected multi-energy microgrids using multi-agent deep reinforcement learning," *IEEE Trans. Smart Grid*, vol. 13, no. 1, pp. 715–727, Jan. 2022.
- [5] H. Li, F. Li, Y. Xu, D. T. Rizy, and S. Adhikari, "Autonomous and adaptive voltage control using multiple distributed energy resources," *IEEE Trans. Power Syst.*, vol. 28, no. 2, pp. 718–730, May 2013.
- [6] B. She, F. Li, H. Cui, J. Wang, Q. Zhang, and R. Bo, "Virtual inertia scheduling for power systems with high penetration of inverter-based resources," 2022, *arXiv:2209.06677*.
- [7] C. Ju, P. Wang, L. Goel, and Y. Xu, "A two-layer energy management system for microgrids with hybrid energy storage considering degradation costs," *IEEE Trans. Smart Grid*, vol. 9, no. 6, pp. 6047–6057, Nov. 2018.
- [8] M. Rezkallah, A. Chandra, B. Singh, and S. Singh, "Microgrid: Configurations, control and applications," *IEEE Trans. Smart Grid*, vol. 10, no. 2, pp. 1290–1302, Mar. 2019.
- [9] N. Nikmehr and S. N. Ravadanegh, "Optimal power dispatch of multi-microgrids at future smart distribution grids," *IEEE Trans. Smart Grid*, vol. 6, no. 4, pp. 1648–1657, Jul. 2015.
- [10] B. She, Y. Dong, and Y. Liu, "Time delay of wide area damping control in urban power grid: Model-based analysis and data-driven compensation," *Front. Energy Res.*, p. 526, Apr. 2022, Art. no. 895163.
- [11] A. Bidram and A. Davoudi, "Hierarchical structure of microgrids control system," *IEEE Trans. Smart Grid*, vol. 3, no. 4, pp. 1963–1976, Dec. 2012.
- [12] D. Wu, F. Tang, T. Dragicevic, J. C. Vasquez, and J. M. Guerrero, "A control architecture to coordinate renewable energy sources and energy storage systems in islanded microgrids," *IEEE Trans. Smart Grid*, vol. 6, no. 3, pp. 1156–1166, May 2015.
- [13] B. Adineh, R. Keypour, P. Davari, and F. Blaabjerg, "Review of harmonic mitigation methods in microgrid: From a hierarchical control perspective," *IEEE J. Emerg. Sel. Topics Power Electron.*, vol. 9, no. 3, pp. 3044–3060, Jun. 2021.
- [14] J. M. Guerrero, M. Chandorkar, T.-L. Lee, and P. C. Loh, "Advanced control architectures for intelligent microgrids—Part I: Decentralized and hierarchical control," *IEEE Trans. Ind. Electron.*, vol. 60, no. 4, pp. 1254–1262, Apr. 2013.
- [15] M. H. Andishgar, E. Gholipour, and R.-A. Hooshmand, "An overview of control approaches of inverter-based microgrids in islanding mode of operation," *Renew. Sustain. Energy Rev.*, vol. 80, pp. 1043–1060, Dec. 2017.
- [16] M. Ahmed, L. Meegahapola, A. Vahidnia, and M. Datta, "Stability and control aspects of microgrid architectures—A comprehensive review," *IEEE Access*, vol. 8, pp. 144730–144766, 2020.
- [17] Y. Han, K. Zhang, H. Li, E. A. A. Coelho, and J. M. Guerrero, "MAS-based distributed coordinated control and optimization in microgrid and microgrid clusters: A comprehensive overview," *IEEE Trans. Power Electron.*, vol. 33, no. 8, pp. 6488–6508, Aug. 2018.
- [18] R. R. Deshmukh, M. S. Ballal, and H. M. Suryawanshi, "A fuzzy logic based supervisory control for power management in multibus DC microgrid," *IEEE Trans. Ind. Appl.*, vol. 56, no. 6, pp. 6174–6185, Nov./Dec. 2020.
- [19] P. Garcia-Trivino, J. P. Torreglosa, L. M. Fernandez-Ramirez, and F. Jurado, "Decentralized fuzzy logic control of microgrid for electric vehicle charging station," *IEEE J. Emerg. Sel. Topics Power Electron.*, vol. 6, no. 2, pp. 726–737, Jun. 2018.
- [20] H. Zhang, J. Zhou, Q. Sun, J. M. Guerrero, and D. Ma, "Data-driven control for interlinked AC/DC microgrids via model-free adaptive control and dual-droop control," *IEEE Trans. Smart Grid*, vol. 8, no. 2, pp. 557–571, Mar. 2017.
- [21] W. Zhang, D. Xu, B. Jiang, and T. Pan, "Prescribed performance based model-free adaptive sliding mode constrained control for a class of nonlinear systems," *Inf. Sci.*, vol. 544, pp. 97–116, Jan. 2021.
- [22] F. Rodríguez, A. M. Florez-Tapia, L. Fontán, and A. Galarza, "Very short-term wind power density forecasting through artificial neural networks for microgrid control," *Renew. Energy*, vol. 145, pp. 1517–1527, Jan. 2020.
- [23] F.-J. Lin, C.-I. Chen, G.-D. Xiao, and P.-R. Chen, "Voltage stabilization control for microgrid with asymmetric membership function-based wavelet petri fuzzy neural network," *IEEE Trans. Smart Grid*, vol. 12, no. 5, pp. 3731–3741, Sep. 2021.
- [24] Y. Du et al., "Intelligent multi-zone residential HVAC control strategy based on deep reinforcement learning," *Appl. Energy*, vol. 281, Jan. 2021, Art. no. 116117.

- [25] Y. Du, F. Li, K. Kurte, J. Munk, and H. Zandi, "Demonstration of intelligent HVAC load management with deep reinforcement learning: Real-world experience of machine learning in demand control," *IEEE Power Energy Mag.*, vol. 20, no. 3, pp. 42–53, May/June 2022.
- [26] Z. Peng, J. Hu, Y. Zhao, and B. K. Ghosh, "Understanding the mechanism of human–computer game: A distributed reinforcement learning perspective," *Int. J. Syst. Sci.*, vol. 51, no. 15, pp. 2837–2848, 2020.
- [27] B. R. Kiran et al., "Deep reinforcement learning for autonomous driving: A survey," *IEEE Trans. Intell. Transp. Syst.*, vol. 23, no. 6, pp. 4909–4926, Jun. 2022.
- [28] L. Brunke et al., "Safe learning in robotics: From learning-based control to safe reinforcement learning," *Annu. Rev. Control, Robot., Auton. Syst.*, vol. 5, pp. 411–444, May 2022.
- [29] Z. Zhang, D. Zhang, and R. C. Qiu, "Deep reinforcement learning for power system applications: An overview," *CSEE J. Power Energy Syst.*, vol. 6, no. 1, pp. 213–225, 2019.
- [30] J. Degraeve et al., "Magnetic control of tokamak plasmas through deep reinforcement learning," *Nature*, vol. 602, no. 7897, pp. 414–419, 2022.
- [31] A. A. Anderson and S. Suryanarayanan, "Review of energy management and planning of islanded microgrids," *CSEE J. Power Energy Syst.*, vol. 6, no. 2, pp. 329–343, 2019.
- [32] T. Hathiyaldeniye, C. Karawita, B. Bagen, N. Pahalawaththa, and U. Annakkage, "Optimal controllers to improve transient recovery of grid-following inverters connected to weak power grids," *IEEE Open Access J. Power Energy*, vol. 9, pp. 161–172, 2022.
- [33] S. D'Silva, M. B. Shadmand, and H. Abu-Rub, "Microgrid control strategies for seamless transition between grid-connected and islanded modes," in *Proc. IEEE Texas Power Energy Conf. (TPEC)*, 2020, pp. 1–6.
- [34] *IEEE Standard for the Specification of Microgrid Controllers*, IEEE Standard 2030.7-2017, 2017.
- [35] B. She, F. Li, H. Cui, J. Wang, O. O. Snapps, and R. Bo, "Decentralized and coordinated Vf control for islanded microgrids considering DER inadequacy and demand control," 2022, *arXiv:2206.11407*.
- [36] W. Du et al., "A comparative study of two widely used grid-forming droop controls on microgrid small-signal stability," *IEEE J. Emerg. Sel. Topics Power Electron.*, vol. 8, no. 2, pp. 963–975, Jun. 2020.
- [37] H. Li, F. Li, Y. Xu, D. T. Rizy, and J. D. Kueck, "Adaptive voltage control with distributed energy resources: Algorithm, theoretical analysis, simulation, and field test verification," *IEEE Trans. Power Syst.*, vol. 25, no. 3, pp. 1638–1647, Aug. 2010.
- [38] J. Rocabert, A. Luna, F. Blaabjerg, and P. Rodriguez, "Control of power converters in AC microgrids," *IEEE Trans. Power Electron.*, vol. 27, no. 11, pp. 4734–4749, Nov. 2012.
- [39] E. Rokrok, M. Shafie-Khah, and J. P. Catalão, "Review of primary voltage and frequency control methods for inverter-based islanded microgrids with distributed generation," *Renew. Sustain. Energy Rev.*, vol. 82, pp. 3225–3235, Feb. 2018.
- [40] Y. Khayat et al., "On the secondary control architectures of AC microgrids: An overview," *IEEE Trans. Power Electron.*, vol. 35, no. 6, pp. 6482–6500, Jun. 2020.
- [41] P. Singh, P. Paliwal, and A. Arya, "A review on challenges and techniques for secondary control of microgrid," in *Proc. IOP Conf. Ser. Mater. Sci. Eng.*, vol. 561, 2019, Art. no. 12075.
- [42] P. Xie et al., "Optimization-based power and energy management system in shipboard microgrid: A review," *IEEE Syst. J.*, vol. 16, no. 1, pp. 578–590, Mar. 2022.
- [43] D. Kanakadhurga and N. Prabaharan, "Demand side management in microgrid: A critical review of key issues and recent trends," *Renew. Sustain. Energy Rev.*, vol. 156, Mar. 2022, Art. no. 111915.
- [44] J. Almada, R. Leão, R. Sampaio, and G. Barroso, "A centralized and heuristic approach for energy management of an AC microgrid," *Renew. Sustain. Energy Rev.*, vol. 60, pp. 1396–1404, Jul. 2016.
- [45] E. Espina, J. Llanos, C. Burgos-Mellado, R. Cardenas-Dobson, M. Martinez-Gomez, and D. Sáez, "Distributed control strategies for microgrids: An overview," *IEEE Access*, vol. 8, pp. 193412–193448, 2020.
- [46] A. Singhal, T. L. Vu, and W. Du, "Consensus control for coordinating grid-forming and grid-following inverters in microgrids," *IEEE Trans. Smart Grid*, vol. 13, no. 5, pp. 4123–4133, Sep. 2022.
- [47] A. K. Sahoo, K. Mahmud, M. Crittenden, J. Ravishankar, S. Padmanaban, and F. Blaabjerg, "Communication-less primary and secondary control in inverter-interfaced AC microgrid: An overview," *IEEE J. Emerg. Sel. Topics Power Electron.*, vol. 9, no. 5, pp. 5164–5182, Oct. 2021.
- [48] O. Babayomi et al., "Advances and opportunities in the model predictive control of microgrids: Part II—Secondary and tertiary layers," *Int. J. Electr. Power Energy Syst.*, vol. 134, Jan. 2022, Art. no. 107339.
- [49] F. Mohammadi et al., "Robust control strategies for microgrids: A review," *IEEE Syst. J.*, vol. 16, no. 2, pp. 2401–2412, Jun. 2022.
- [50] K. Moharm, "State of the art in big data applications in microgrid: A review," *Adv. Eng. Inform.*, vol. 42, Oct. 2019, Art. no. 100945.
- [51] S. Aslam, H. Herodotou, S. M. Mohsin, N. Javaid, N. Ashraf, and S. Aslam, "A survey on deep learning methods for power load and renewable energy forecasting in smart microgrids," *Renew. Sustain. Energy Rev.*, vol. 144, Jul. 2021, Art. no. 110992.
- [52] S. Zafar, M. A. Amin, B. Javaid, and H. A. Khalid, "On design of DC-link voltage controller and PQ controller for grid connected VSC for microgrid application," in *Proc. Int. Conf. Power Gener. Syst. Renew. Energy Technol. (PGSRET)*, 2018, pp. 1–6.
- [53] S. Dinkhah, J. S. Cuellar, and M. Khanbaghi, "Optimal power and frequency control of Microgrid cluster with mixed loads," *IEEE Open Access J. Power Energy*, vol. 9, pp. 143–150, 2022.
- [54] Z. Qu, J. C.-H. Peng, H. Yang, and D. Srinivasan, "Modeling and analysis of inner controls effects on damping and synchronizing torque components in VSG-controlled converter," *IEEE Trans. Energy Convers.*, vol. 36, no. 1, pp. 488–499, Mar. 2021.
- [55] X. Hou, Y. Sun, X. Zhang, J. Lu, P. Wang, and J. M. Guerrero, "Improvement of frequency regulation in VSG-based AC microgrid via adaptive virtual inertia," *IEEE Trans. Power Electron.*, vol. 35, no. 2, pp. 1589–1602, Feb. 2020.
- [56] H. Zhang, W. Xiang, W. Lin, and J. Wen, "Grid forming converters in renewable energy sources dominated power grid: Control strategy, stability, application, and challenges," *J. Modern Power Syst. Clean Energy*, vol. 9, no. 6, pp. 1239–1256, Nov. 2021.
- [57] C. Huang, H. Zhang, Y. Song, L. Wang, T. Ahmad, and X. Luo, "Demand response for industrial micro-grid considering photovoltaic power uncertainty and battery operational cost," *IEEE Trans. Smart Grid*, vol. 12, no. 4, pp. 3043–3055, Jul. 2021.
- [58] Y. Levron, J. M. Guerrero, and Y. Beck, "Optimal power flow in microgrids with energy storage," *IEEE Trans. Power Syst.*, vol. 28, no. 3, pp. 3226–3234, Aug. 2013.
- [59] Z. Wang et al., "Adaptive harmonic impedance reshaping control strategy based on a consensus algorithm for harmonic sharing and power quality improvement in microgrids with complex feeder networks," *IEEE Trans. Smart Grid*, vol. 13, no. 1, pp. 47–57, Jan. 2022.
- [60] I. De Mel, O. V. Klymenko, and M. Short, "Balancing accuracy and complexity in optimisation models of distributed energy systems and microgrids with optimal power flow: A review," *Sustain. Energy Technol. Assess.*, vol. 52, Aug. 2022, Art. no. 102066.
- [61] S. P. Bihari et al., "A comprehensive review of microgrid control mechanism and impact assessment for hybrid renewable energy integration," *IEEE Access*, vol. 9, pp. 88942–88958, 2021.
- [62] Y. Gao and N. Yu, "Deep reinforcement learning in power distribution systems: Overview, challenges, and opportunities," in *Proc. IEEE Power Energy Soc. Innovative Smart Grid Technol. Conf. (ISGT)*, 2021, pp. 1–5.
- [63] X. Chen, G. Qu, Y. Tang, S. Low, and N. Li, "Reinforcement learning for decision-making and control in power systems: Tutorial, review, and vision," 2021, *arXiv:2102.01168*.
- [64] H. Shuai, F. Li, H. Pulgar-Painemal, and Y. Xue, "Branching dueling Q-network-based online scheduling of a microgrid with distributed energy storage systems," *IEEE Trans. Smart Grid*, vol. 12, no. 6, pp. 5479–5482, Nov. 2021.
- [65] J. Tsitsiklis and B. Van Roy, "An analysis of temporal-difference learning with function approximation," *Lab. Inf. Decis. Syst.*, Massachusetts Inst. Technol., Cambridge, MA, USA, Rep. LIDS-P-2322, 1996.
- [66] J. N. Tsitsiklis, "Asynchronous stochastic approximation and Q-learning," *Mach. Learn.*, vol. 16, no. 3, pp. 185–202, 1994.
- [67] J. Chung, "Playing Atari with deep reinforcement learning," in *Proc. NIPS*, vol. 21, Dec. 2013, pp. 351–362.
- [68] H. Van Hasselt, A. Guez, and D. Silver, "Deep reinforcement learning with double Q-learning," in *Proc. AAAI Conf. Artif. Intell.*, vol. 30, 2016, pp. 2094–2100.
- [69] M. G. Bellemare, W. Dabney, and R. Munos, "A distributional perspective on reinforcement learning," in *Proc. Int. Conf. Mach. Learn.*, 2017, pp. 449–458.
- [70] W. Dabney, M. Rowland, M. Bellemare, and R. Munos, "Distributional reinforcement learning with quantile regression," in *Proc. AAAI Conf. Artif. Intell.*, vol. 32, 2018, pp. 2892–2901.

- [71] M. Hessel et al., "Rainbow: Combining improvements in deep reinforcement learning," in *Proc. 32nd AAAI Conf. Artif. Intell.*, 2018, pp. 3215–3222.
- [72] R. S. Sutton, D. McAllester, S. Singh, and Y. Mansour, "Policy gradient methods for reinforcement learning with function approximation," in *Proc. Adv. Neural Inf. Process. Syst.*, vol. 12, 1999, pp. 1–7.
- [73] J. Schulman, S. Levine, P. Abbeel, M. Jordan, and P. Moritz, "Trust region policy optimization," in *Proc. Int. Conf. Mach. Learn.*, 2015, pp. 1889–1897.
- [74] J. Schulman, F. Wolski, P. Dhariwal, A. Radford, and O. Klimov, "Proximal policy optimization algorithms," 2017, *arXiv:1707.06347*.
- [75] K. W. Cobbe, J. Hilton, O. Klimov, and J. Schulman, "Phasic policy gradient," in *Proc. Int. Conf. Mach. Learn.*, 2021, pp. 2020–2027.
- [76] V. Mnih et al., "Asynchronous methods for deep reinforcement learning," in *Proc. Int. Conf. Mach. Learn.*, 2016, pp. 1928–1937.
- [77] T. Haarnoja, A. Zhou, P. Abbeel, and S. Levine, "Soft actor-critic: Off-policy maximum entropy deep reinforcement learning with a stochastic actor," in *Proc. Int. Conf. Mach. Learn.*, 2018, pp. 1861–1870.
- [78] D. Silver, G. Lever, N. Heess, T. Degris, D. Wierstra, and M. Riedmiller, "Deterministic policy gradient algorithms," in *Proc. Int. Conf. Mach. Learn.*, 2014, pp. 387–395.
- [79] T. P. Lillicrap et al., "Continuous control with deep reinforcement learning," 2015, *arXiv:1509.02971*.
- [80] X. Chen, G. Qu, Y. Tang, S. Low, and N. Li, "Reinforcement learning for selective key applications in power systems: Recent advances and future challenges," *IEEE Trans. Smart Grid*, vol. 13, no. 4, pp. 2935–2958, Jul. 2022.
- [81] D. Chen et al., "Powernet: Multi-agent deep reinforcement learning for scalable powergrid control," *IEEE Trans. Power Syst.*, vol. 37, no. 2, pp. 1007–1017, Mar. 2021.
- [82] M. Gheisarnajad, H. Farsizadeh, and M. H. Khooban, "A novel nonlinear deep reinforcement learning controller for DC–DC power buck converters," *IEEE Trans. Ind. Electron.*, vol. 68, no. 8, pp. 6849–6858, Aug. 2021.
- [83] C. Samende, J. Cao, and Z. Fan, "Multi-agent deep deterministic policy gradient algorithm for peer-to-peer energy trading considering distribution network constraints," *Appl. Energy*, vol. 317, Jul. 2022, Art. no. 119123.
- [84] H. Shuai and H. He, "Online scheduling of a residential microgrid via Monte-Carlo tree search and a learned model," *IEEE Trans. Smart Grid*, vol. 12, no. 2, pp. 1073–1087, Mar. 2021.
- [85] S. Wang, R. Diao, C. Xu, D. Shi, and Z. Wang, "On multi-event co-calibration of dynamic model parameters using soft actor-critic," *IEEE Trans. Power Syst.*, vol. 36, no. 1, pp. 521–524, Jan. 2021.
- [86] A. J. Abianeh, Y. Wan, F. Ferdowsi, N. Mijatovic, and T. Dragičević, "Vulnerability identification and remediation of FDI attacks in islanded DC microgrids using multiagent reinforcement learning," *IEEE Trans. Power Electron.*, vol. 37, no. 6, pp. 6359–6370, Jun. 2022.
- [87] E. O. Arwa and K. A. Folly, "Reinforcement learning techniques for optimal power control in grid-connected microgrids: A comprehensive review," *IEEE Access*, vol. 8, pp. 208992–209007, 2020.
- [88] M. Hajhosseini, M. Andalibi, M. Gheisarnajad, H. Farsizadeh, and M.-H. Khooban, "DC/DC power converter control-based deep machine learning techniques: Real-time implementation," *IEEE Trans. Power Electron.*, vol. 35, no. 10, pp. 9971–9977, Oct. 2020.
- [89] C. Neal, H. Dagdougui, A. Lodi, and J. M. Fernandez, "Reinforcement learning based penetration testing of a microgrid control algorithm," in *Proc. IEEE 11th Annu. Comput. Commun. Workshop Conf. (CCWC)*, 2021, pp. 38–44.
- [90] M. Adibi and J. Van der Woude, "Secondary frequency control of microgrids: An online reinforcement learning approach," *IEEE Trans. Autom. Control*, vol. 67, no. 9, pp. 4824–4831, Sep. 2022.
- [91] Y. Li, Z. Xu, K. B. Bowes, and L. Ren, "Reinforcement learning-enabled seamless microgrids interconnection," in *Proc. IEEE Power Energy Soc. Gen. Meeting (PESGM)*, 2021, pp. 1–5.
- [92] M. H. Khooban and M. Gheisarnajad, "A novel deep reinforcement learning controller based type-II fuzzy system: Frequency regulation in microgrids," *IEEE Trans. Emerg. Topics Comput. Intell.*, vol. 5, no. 4, pp. 689–699, Aug. 2021.
- [93] Y. Du and F. Li, "Intelligent multi-microgrid energy management based on deep neural network and model-free reinforcement learning," *IEEE Trans. Smart Grid*, vol. 11, no. 2, pp. 1066–1076, Mar. 2020.
- [94] Z. Yan, Y. Xu, Y. Wang, and X. Feng, "Data-driven economic control of battery energy storage system considering battery degradation," in *Proc. 9th Int. Conf. Power Energy Syst. (ICPES)*, 2019, pp. 1–5.
- [95] J. Duan, Z. Yi, D. Shi, C. Lin, X. Lu, and Z. Wang, "Reinforcement-learning-based optimal control of hybrid energy storage systems in hybrid AC–DC microgrids," *IEEE Trans. Ind. Informat.*, vol. 15, no. 9, pp. 5355–5364, Sep. 2019.
- [96] M. Elsayed, M. Erol-Kantarci, B. Kantarci, L. Wu, and J. Li, "Low-latency communications for community resilience microgrids: A reinforcement learning approach," *IEEE Trans. Smart Grid*, vol. 11, no. 2, pp. 1091–1099, Mar. 2020.
- [97] C. Wang, S. Mei, H. Yu, S. Cheng, L. Du, and P. Yang, "Unintentional islanding transition control strategy for three-/single-phase multimicrogrids based on artificial emotional reinforcement learning," *IEEE Syst. J.*, vol. 15, no. 4, pp. 5464–5475, Dec. 2021.
- [98] H. Song, Y. Liu, J. Zhao, J. Liu, and G. Wu, "Prioritized replay dueling DDQN based grid-edge control of community energy storage system," *IEEE Trans. Smart Grid*, vol. 12, no. 6, pp. 4950–4961, Nov. 2021.
- [99] L. Xiong et al., "A two-level energy management strategy for multi-microgrid systems with interval prediction and reinforcement learning," *IEEE Trans. Circuits Syst. I, Reg. Papers*, vol. 69, no. 4, pp. 1788–1799, Apr. 2022.
- [100] R. Hao, T. Lu, Q. Ai, and H. He, "Distributed online dispatch for microgrids using hierarchical reinforcement learning embedded with operation knowledge," *IEEE Trans. Power Syst.*, early access, Jun. 24, 2021, doi: [10.1109/TPWRS.2021.3092220](https://doi.org/10.1109/TPWRS.2021.3092220).
- [101] H. K. Høidalen and A. C. O. Rocha, "Analysis of gray box modelling of transformers," *Electr. Power Syst. Res.*, vol. 197, Aug. 2021, Art. no. 107266.
- [102] Q. Shi, F. Li, and H. Cui, "Analytical method to aggregate multi-machine SFR model with applications in power system dynamic studies," *IEEE Trans. Power Syst.*, vol. 33, no. 6, pp. 6355–6367, Nov. 2018.
- [103] H. Cui, F. Li, and K. Tomsovic, "Hybrid symbolic-numeric framework for power system modeling and analysis," *IEEE Trans. Power Syst.*, vol. 36, no. 2, pp. 1373–1384, Mar. 2021.
- [104] J. Liu, Y. Sun, C. Han, Z. Dou, and W. Li, "Deep representation learning on long-tailed data: A learnable embedding augmentation perspective," in *Proc. IEEE/CVF Conf. Comput. Vis. Pattern Recognit.*, 2020, pp. 2970–2979.
- [105] Y. Zhang, J. Liu, F. Qiu, T. Hong, and R. Yao, "Deep active learning for solvability prediction in power systems," *J. Modern Power Syst. Clean Energy*, vol. 10, no. 6, pp. 1773–1777, Nov. 2022.
- [106] V. Charles, J. Aparicio, and J. Zhu, "The curse of dimensionality of decision-making units: A simple approach to increase the discriminatory power of data envelopment analysis," *Eur. J. Oper. Res.*, vol. 279, no. 3, pp. 929–940, 2019.
- [107] S. Khadka and K. Tumer, "Evolutionary reinforcement learning," 2018, *arXiv:1805.07917*.
- [108] A. Vaswani et al., "Attention is all you need," in *Proc. Adv. Neural Inf. Process. Syst.*, vol. 30, 2017, pp. 1–11.
- [109] Q. Li et al., "A survey on federated learning systems: Vision, hype and reality for data privacy and protection," *IEEE Trans. Knowl. Data Eng.*, early access, Nov. 2, 2021, doi: [10.1109/TKDE.2021.3124599](https://doi.org/10.1109/TKDE.2021.3124599).
- [110] K. Cao, Y. Liu, G. Meng, and Q. Sun, "An overview on edge computing research," *IEEE Access*, vol. 8, pp. 85714–85728, 2020.
- [111] R. Agarwal, M. C. Machado, P. S. Castro, and M. G. Bellemare, "Contrastive behavioral similarity embeddings for generalization in reinforcement learning," 2021, *arXiv:2101.05265*.
- [112] H. Liu and W. Wu, "Two-stage deep reinforcement learning for inverter-based volt-var control in active distribution networks," *IEEE Trans. Smart Grid*, vol. 12, no. 3, pp. 2037–2047, May 2021.
- [113] L. Pinto, J. Davidson, R. Sukthankar, and A. Gupta, "Robust adversarial reinforcement learning," in *Proc. Int. Conf. Mach. Learn.*, 2017, pp. 2817–2826.
- [114] S. Junges, N. Jansen, C. Dehnert, U. Topcu, and J.-P. Katoen, "Safety-constrained reinforcement learning for MDPs," in *Proc. Int. Conf. Tools Algorithms Construction Anal. Syst.*, 2016, pp. 130–146.
- [115] Y. Li, N. Li, H. E. Tseng, A. Girard, D. Filev, and I. Kolmanovsky, "Safe reinforcement learning using robust action governor," in *Proc. Learn. Dyn. Control*, 2021, pp. 1093–1104.
- [116] F. Berkenkamp, M. Turchetta, A. Schoellig, and A. Krause, "Safe model-based reinforcement learning with stability guarantees," in *Proc. Adv. Neural Inf. Process. Syst.*, vol. 30, 2017, pp. 1–11.
- [117] B. Huang and J. Wang, "Applications of physics-informed neural networks in power systems—A review," *IEEE Trans. Power Syst.*, early access, Mar. 25, 2022, doi: [10.1109/TPWRS.2022.3162473](https://doi.org/10.1109/TPWRS.2022.3162473).

- [118] N. Hatziaargyriou et al., "Definition and classification of power system stability—revisited & extended," *IEEE Trans. Power Syst.*, vol. 36, no. 4, pp. 3271–3281, Jul. 2021.
- [119] J. Liu, Y. Zhang, A. J. Conejo, and F. Qiu, "Ensuring transient stability with guaranteed region of attraction in DC microgrids," *IEEE Trans. Power Syst.*, early access, Apr. 14, 2022, doi: [10.1109/TPWRS.2022.3167315](https://doi.org/10.1109/TPWRS.2022.3167315).
- [120] Z. Zhang, R. Schuerhuber, L. Fickert, K. Friedl, G. Chen, and Y. Zhang, "Domain of attraction's estimation for grid connected converters with phase-locked loop," *IEEE Trans. Power Syst.*, vol. 37, no. 2, pp. 1351–1362, Mar. 2022.
- [121] Y. Chow, O. Nachum, E. Duenez-Guzman, and M. Ghavamzadeh, "A Lyapunov-based approach to safe reinforcement learning," in *Proc. Adv. Neural Inf. Process. Syst.*, vol. 31, 2018, pp. 8103–8112.
- [122] W. Cui and B. Zhang, "Lyapunov-regularized reinforcement learning for power system transient stability," *IEEE Control Syst. Lett.*, vol. 6, pp. 974–979, 2021.



Hantao Cui (Senior Member, IEEE) received the B.S. and M.S. degrees in electrical engineering from Southeast University, China in 2011 and 2013, and the Ph.D. degree in electrical engineering from the University of Tennessee at Knoxville, Knoxville in 2018. He is currently an Assistant Professor with the School of Electrical and Computer Engineering, Oklahoma State University. His research interests include power system modeling, simulation, and high-performance computing.



Buxin She (Student Member, IEEE) received the B.S.E.E. and M.S.E.E. degrees from Tianjin University, Tianjin, China, in 2017 and 2019, respectively. He is currently pursuing the Ph.D. degree with the Department of Electrical Engineering and Computer Science, The University of Tennessee at Knoxville, Knoxville. His research interests include microgrid operation and control, machine learning in power system, and power grid resilience.



Jingqiu Zhang (Student Member, IEEE) received the B.S. and M.S. degree in electrical engineering from Tianjin University, Tianjin, China, in 2016 and 2019, respectively. He is currently pursuing the Ph.D. degree in electrical and computer engineering with the National University of Singapore, Singapore. His current research interests include cyber security of power grids, distributed control, and optimization in microgrids.



Fangxing Li (Fellow, IEEE) is also known as Fran Li. He received the B.S.E.E. and M.S.E.E. degrees from Southeast University, Nanjing, China, in 1994 and 1997, respectively, and the Ph.D. degree from Virginia Tech, Blacksburg, VA, USA, in 2001.

He is currently the James W. McConnell Professor of Electrical Engineering and the Campus Director of CURENT with the University of Tennessee at Knoxville, Knoxville, TN, USA. His current research interests include resilience, artificial intelligence in power, demand response, distributed generation and microgrid, and energy markets. He has received numerous awards and honors, including the R&D 100 Award in 2020, the IEEE PES Technical Committee Prize Paper Award in 2019, the five Best or Prize Paper Awards at international journals, and the six Best Papers/Posters at international conferences. He has been the Editor-in-Chief of IEEE OPEN ACCESS JOURNAL OF POWER AND ENERGY since 2020. From 2020 to 2021, he served as the Chair of IEEE PES Power System Operation, Planning and Economics Committee. He has been serving as the Chair of IEEE WG on Machine Learning for Power Systems since 2019.

operation and microgrid, and energy markets. He has received numerous awards and honors, including the R&D 100 Award in 2020, the IEEE PES Technical Committee Prize Paper Award in 2019, the five Best or Prize Paper Awards at international journals, and the six Best Papers/Posters at international conferences. He has been the Editor-in-Chief of IEEE OPEN ACCESS JOURNAL OF POWER AND ENERGY since 2020. From 2020 to 2021, he served as the Chair of IEEE PES Power System Operation, Planning and Economics Committee. He has been serving as the Chair of IEEE WG on Machine Learning for Power Systems since 2019.



Rui Bo (Senior Member, IEEE) received the B.S.E.E. and M.S.E.E. degrees in electric power engineering from Southeast University, China, in 2000 and 2003, respectively, and the Ph.D. degree in electrical engineering from the University of Tennessee at Knoxville, Knoxville, in 2009. He is currently an Assistant Professor with the Electrical and Computer Engineering Department, Missouri University of Science and Technology (formerly University of Missouri–Rolla). He worked as a Principal Engineer and the Project Manager with

Midcontinent Independent System Operator from 2009 to 2017. His research interests include computation, optimization and economics in power system operation and planning, high performance computing, electricity market simulation, evaluation, and design.